NEW YORK STATE DEPARTMENT OF AGRICULTURE AND MARKETS
DIVISION OF ANIMAL INDUSTRY
10B AIRLINE DRIVE, ALBANY, NY 12235

MUNICIPAL SHELTER INSPECTION REPORT - DL-90

Rating: **Satisfactory182** Purpose: **Inspection**

DATE/TOA: **12/17/12 11:15 am**

HORNBY SHELTER
5004 CTY. RTE. 42
Beaver Dams NY 14812

Inspector #: **809**

These are the findings of an inspection of your facility on the date(s) indicated above:

1. Shelter is structurally sound	Yes
2. Housing area and equipment is sanitized regularly	Yes
3. Repairs are done when necessary	Yes
4. Dogs are handled safely	Yes
5. Adequate space is available for all dogs	Yes
6. Light is sufficient for observation	Yes
7. Ventilation is adequate	No

There is a distinct "doggie odor" in and around the kennel even though there were no dogs in the kennel at the time of the inspection. It is recommended that an exhaust fan be installed to improve air movement.

8. Drainage is adequate	Yes
9. Temperature extremes are avoided	Yes
10. Clean food and water is available and in ample amount	Yes
11. Veterinary care is provided when necessary	Not Applicable
12. Dogs are euthanized humanely, by authorized personnel	Not Applicable
13. Complete intake and disposition records are maintained for all seized dogs	Not Applicable
14. Dogs transferred for purposes of adoption in compliance with Article 7	Not Applicable
15. Redemption period is observed before adoption, euthanasia or transfer	Not Applicable
16. Owners of identified dogs are properly notified	Not Applicable
17. Redeemed dogs are licensed before release	Not Applicable
18. Proper impoundment fees paid before dogs are released	Not Applicable
19. Written contract or lease with municipality	Not Applicable

Town - City - Village Information for Inspection:

TCV CODE	TCV NAME
4616	Town of Hornby

REMARKS:

The shelter corrected the deficiencies noted in the last inspection. New wood panels were placed in each of the kennels that are used to house dogs. The kennels no longer pose a danger to the dogs that are housed in them. The ventilation is still less than adequate and it is recommended that an exhaust fan be installed. An old piece of furniture remains in the kennel that has no real purpose. It is recommended that this be removed. The DCO's were not able to meet me at the shelter so the inspection was unannounced and one of the highway workers (who used to be the DCO) had the key to the kennel and allowed me to inspect it. There was no paperwork to review at this time.

REPRESENTATIVE PRESENT FOR INSPECTION: **Gardiner Bills**
TITLE: **highway worker**

REVIEWED BY:
REVIEWED DATE: **12/18/2012**