NEW YORK STATE DEPARTMENT OF AGRICULTURE AND MARKETS
DIVISION OF ANIMAL INDUSTRY
10B AIRLINE DRIVE, ALBANY, NY 12235

MUNICIPAL SHELTER INSPECTION REPORT - DL-90

Rating: **Unsatisfactory30** Purpose: **Inspection**

DATE/TOA: **2/12/18 1:30 pm**

ANIMAL SAFE-HOME AND REHABILITATION, LLC
NANCY QUELL & ED HOLLAND
298 FERGUSON ROAD
COSSAYUNA NY 12823

Inspector #: **58**
Inspector #: **50**

These are the findings of an inspection of your facility on the date(s) indicated above:

1. Shelter is structurally sound — No

Roof on back side of shelter is leaking. Ceilings in the kennels are warped and moldy from being exposed to excessive water.
Electrical hazards were observed on vacant side of kennel. Water was leaking around the light fixtures attached to the ceiling.

2. Housing area and equipment is sanitized regularly — No

Back walls of kennels are not adequately sealed to allow for proper cleaning and disinfecting surface area.
Disinfectant available is insufficient to effectively disinfect housing area and kennels. There was no active ingredient listed on bleach product provided.
Kennel pull out trays were filled with excess fecal material.
A blanket covered in feces was left in kennel area on top of a disconnected propane tank

3. Repairs are done when necessary — No

Chain link on kennel doors and metal bars are rusty.

4. Dogs are handled safely — Yes

5. Adequate space is available for all dogs — Yes

6. Light is sufficient for observation — No

Lighting was very dim. Unable to adequately observe kennels for cleanliness without pulling out trays.

7. Ventilation is adequate — No

Strong ammonia smell was present upon entering the shelter/kennel area

8. Drainage is adequate — No

Floors were damp in kennel area. There was standing water present on the vacant side of the shelter area.

9. Temperature extremes are avoided — No

Heat source did not appear to be working upon arrival for inspection. Heating system was blowing cold air in the kennel. It was 35 degrees F outside on the day of the inspection. The kennel area was very cold upon entering. A thermometer is not present in the housing area.

10. Clean food and water is available and in ample amount — No

Not all food was stored in covered containers. Observed open bags of food and boxes of biscuits in kennel area.

11. Veterinary care is provided when necessary — Yes

12. Dogs are euthanized humanely, by authorized personnel — Not Applicable

13. Complete intake and disposition records are maintained for all seized dogs — Not Applicable

14. Dogs transferred for purposes of adoption in compliance with Article 7 — Not Applicable

15. Redemption period is observed before adoption, euthanasia or transfer — Not Applicable

16. Owners of identified dogs are properly notified — Not Applicable

17. Redeemed dogs are licensed before release — Not Applicable

18. Proper impoundment fees paid before dogs are released — Not Applicable

19. Written contract or lease with municipality No

Written contracts for 2018 were unavailable for review during inspection

Town - City - Village Information for Inspection:

TCV CODE	TCV NAME
5304	Town of Easton
5301	Town of Argyle
5302	Town of Cambridge
5307	Town of Granville
5308	Town of Greenwich
5309	Town of Hampton
5310	Town of Hartford
5311	Town of Hebron
3805	Town of Hoosick
5315	Town of Salem
5316	Town of White Creek
5317	Town of Whitehall
5312	Town of Jackson
3808	Town of Petersburgh

REMARKS:

N/A = Handled by DCO Quell and Holland

REPRESENTATIVE PRESENT FOR INSPECTION: **Ed Holland**
TITLE: **ACO**

REVIEWED BY: **Inspector #: 50**
REVIEWED DATE: **02/13/2018**