

MUNICIPAL SHELTER INSPECTION REPORT - DL-90

Rating: **Unsatisfactory30**

Purpose: **Inspection**

DATE/TOA: **7/5/18 2:45 pm**

**HORNBY SHELTER
 5004 CTY. RTE. 42
 Beaver Dams NY 14812**

Inspector #: **68**

These are the findings of an inspection of your facility on the date(s) indicated above:

- | | |
|---|----------------|
| 1. Shelter is structurally sound | Yes |
| 2. Housing area and equipment is sanitized regularly | Yes |
| 3. Repairs are done when necessary | No |
| <i>Chain link panel between end and middle kennel is rusty which inhibits effective disinfection of kennels. It should be painted.</i> | |
| <i>The middle support beam on the exterior kennel runs in not supporting any weight from the roof of the runs. The bottom end of the beam is rotten and swings from the roof.</i> | |
| 4. Dogs are handled safely | Yes |
| 5. Adequate space is available for all dogs | Yes |
| 6. Light is sufficient for observation | Yes |
| 7. Ventilation is adequate | Yes |
| 8. Drainage is adequate | Yes |
| 9. Temperature extremes are avoided | Yes |
| 10. Clean food and water is available and in ample amount | Yes |
| 11. Veterinary care is provided when necessary | Yes |
| 12. Dogs are euthanized humanely, by authorized personnel | Yes |
| 13. Complete intake and disposition records are maintained for all seized dogs | Yes |
| 14. Dogs transferred for purposes of adoption in compliance with Article 7 | Yes |
| 15. Redemption period is observed before adoption, euthanasia or transfer | Yes |
| 16. Owners of identified dogs are properly notified | Yes |
| 17. Redeemed dogs are licensed before release | Yes |
| 18. Proper impoundment fees paid before dogs are released | Yes |
| 19. Written contract or lease with municipality | Not Applicable |

Town - City - Village Information for Inspection:

<u>TCV CODE</u>	<u>TCV NAME</u>
4616	Town of Hornby

REMARKS:

Entry was gained due to unlocked shelter door.

REPRESENTATIVE PRESENT FOR INSPECTION: **N/A**
TITLE: **N/A**

REVIEWED BY: **Inspector #: 50**
REVIEWED DATE: **07/13/2018**