NEW YORK STATE DEPARTMENT OF AGRICULTURE AND MARKETS
DIVISION OF ANIMAL INDUSTRY
10B AIRLINE DRIVE, ALBANY, NY 12235

MUNICIPAL SHELTER INSPECTION REPORT - DL-90

Rating: **Unsatisfactory30** Purpose: **Inspection**

DATE/TOA: **9/2/20 12:30 pm**

MONTGOMERY COUNTY SPCA
ASHLEY WEIL, SHELTER MANAGER
1007 RT 5S
AMSTERDAM NY 12010

Inspector #: **50**
Inspector #: **54**

These are the findings of an inspection of your facility on the date(s) indicated above:

1. Shelter is structurally sound	Yes
2. Housing area and equipment is sanitized regularly	Yes
3. Repairs are done when necessary	No

Rusty chain link in dog kennels not sufficiently made impervious. Surfaces remain rough and impossible to properly disinfect to prevent disease transmission.
There are numerous broken, rusty, sharp rails rails on the bottom of kennel doors and frames presenting an injury hazard. These must be repaired without delay or must not be used to house animals.

4. Dogs are handled safely	Yes
5. Adequate space is available for all dogs	Yes
6. Light is sufficient for observation	Yes
7. Ventilation is adequate	Yes
8. Drainage is adequate	No

Floor drain in dog isolation room is full of wastewater presenting a disease hazard.

9. Temperature extremes are avoided	Yes
10. Clean food and water is available and in ample amount	Yes
11. Veterinary care is provided when necessary	Yes
12. Dogs are euthanized humanely, by authorized personnel	Yes
13. Complete intake and disposition records are maintained for all seized dogs	Yes
14. Dogs transferred for purposes of adoption in compliance with Article 7	Yes
15. Redemption period is observed before adoption, euthanasia or transfer	Yes
16. Owners of identified dogs are properly notified	Not Applicable

DCO's handle

17. Redeemed dogs are licensed before release	Yes
18. Proper impoundment fees paid before dogs are released	Yes
19. Written contract or lease with municipality	Yes

Town - City - Village Information for Inspection:

TCV CODE	TCV NAME
2704	Town of Florida
2701	Town of Amsterdam
1709	Town of Perth
2711	City of Amsterdam

REMARKS:

Shelter is planning to construct a new facility at a different location.

REPRESENTATIVE PRESENT FOR INSPECTION: **Ashley Weil**
TITLE: **Shelter manager**

REVIEWED BY: **Inspector #: 833**
REVIEWED DATE: **09/11/2020**