

MUNICIPAL SHELTER INSPECTION REPORT - DL-90

Rating: **Unsatisfactory30**

Purpose: **Inspection**

DATE/TOA: **11/20/20 10:45 am**

**HUMANE SOCIETY OF WALDEN
 2489 ALBANY POST ROAD
 WALDEN NY 12586**

Inspector #: **67**

These are the findings of an inspection of your facility on the date(s) indicated above:

- | | |
|--|-----|
| 1. Shelter is structurally sound | Yes |
| 2. Housing area and equipment is sanitized regularly | Yes |
| 3. Repairs are done when necessary | No |
| <i>Exterior kennel runs on the "back side of the building", from entry door:- kennels 2 and 7 have gate cross bar fully rusted through with dogs contained. The concern is injury to the dogs' feet when jumping up at the gate.</i> | |
| 4. Dogs are handled safely | Yes |
| 5. Adequate space is available for all dogs | Yes |
| 6. Light is sufficient for observation | Yes |
| 7. Ventilation is adequate | Yes |
| 8. Drainage is adequate | Yes |
| 9. Temperature extremes are avoided | Yes |
| 10. Clean food and water is available and in ample amount | Yes |
| 11. Veterinary care is provided when necessary | Yes |
| 12. Dogs are euthanized humanely, by authorized personnel | Yes |
| 13. Complete intake and disposition records are maintained for all seized dogs | Yes |
| 14. Dogs transferred for purposes of adoption in compliance with Article 7 | Yes |
| 15. Redemption period is observed before adoption, euthanasia or transfer | Yes |
| 16. Owners of identified dogs are properly notified | Yes |
| 17. Redeemed dogs are licensed before release | Yes |
| 18. Proper impoundment fees paid before dogs are released | Yes |
| 19. Written contract or lease with municipality | Yes |

 Town - City - Village Information for Inspection:

TCV CODE	TCV NAME
3304	Town of Crawford
4811	Town of Mamakating
3312	Town of Montgomery
3303	Town of Cornwall
5117	Town of Shawangunk
5119	Town of Wawarsing

REMARKS:

Many of the exterior kennel runs connected to the interior housing are in need of repair or re sealing, but were not in use at the time of inspection.

Please note the following repairs necessary before dogs are to utilize these runs.

Exterior runs on the "entry" side of the building, starting numerically from entry gate to runs - runs 1-5 require concrete cracks to filled and concrete floor resealed; runs 6-9 have "pitting" of the concrete that needs to be filled and resealed; runs 5 requires replacement of gate as cross bar support rusted through with sharp edges (safety concern); runs 9 & 10 have chain link fencing supports rusted and broken in need of replacing. (safety concern). Much of the chain link fencing is rusted and in need of attention.

Exterior kennel runs on the "back" side of the building, starting numerically from the entry gate to runs - kennel 1 has chain link support in need of repair; runs 2,3,4,&7 have rusted cross bar support in gates that require repair or replacement of gate; kennel 9 needs crack in concrete floor filled and resealed; kennel 11 requires concrete erosion of guillotine saddle to be repaired.

Interior "front cage" should have cover over floor drain opening to prevent dog from stepping in it; holes in walls need to be repaired - plaster exposing lathe and insulation behind and concrete holes where previous plumbing came through.

Any questions regarding these repairs can be directed to Inspector Amels 845-500-1498.

REPRESENTATIVE PRESENT FOR INSPECTION:
TITLE: **shelter staff**

Lisa Rodriguez

REVIEWED BY: **Inspector #: 18**
REVIEWED DATE: **11/30/2020**