NEW YORK STATE DEPARTMENT OF AGRICULTURE AND MARKETS
DIVISION OF ANIMAL INDUSTRY
10B AIRLINE DRIVE, ALBANY, NY 12235

MUNICIPAL SHELTER INSPECTION REPORT - DL-90

Rating: **Unsatisfactory30** Purpose: **Inspection**

DATE/TOA: **6/14/22 6:15 pm**

TOWN OF WHEATLAND SHELTER
1822 SCOTTSVILLE-MUMFORD RD
SCOTTSVILLE NY 14546

Inspector #: **72**

These are the findings of an inspection of your facility on the date(s) indicated above:

1. Shelter is structurally sound	Yes
2. Housing area and equipment is sanitized regularly	No
See Remarks	
3. Repairs are done when necessary	No
The floor is cracked and not sealed in the kennel area making it not able to be properly disinfected.	
4. Dogs are handled safely	Yes
5. Adequate space is available for all dogs	Yes
6. Light is sufficient for observation	Yes
7. Ventilation is adequate	No
There is no adequate ventilation for the temperature extremes and cleaning.	
8. Drainage is adequate	Yes
9. Temperature extremes are avoided	Yes
10. Clean food and water is available and in ample amount	Yes
11. Veterinary care is provided when necessary	Yes
12. Dogs are euthanized humanely, by authorized personnel	Yes
13. Complete intake and disposition records are maintained for all seized dogs	Yes
14. Dogs transferred for purposes of adoption in compliance with Article 7	Yes
15. Redemption period is observed before adoption, euthanasia or transfer	Yes
16. Owners of identified dogs are properly notified	Yes
17. Redeemed dogs are licensed before release	Yes
18. Proper impoundment fees paid before dogs are released	Yes
19. Written contract or lease with municipality	Not Applicable
Muncipality owned	

Town - City - Village Information for Inspection:

TCV CODE	TCV NAME
2619	Town of Wheatland

REMARKS:

According to Agriculture & Markets Article 7, all seized dogs must have proper care while sheltered. This includes adequate ventilation during temperature extremes. The floors must be adequately cleaned and disinfected and to do this the floor must be a non-porous surface. We discussed at the inspection sealing the floor to make it a surface that can be sanitized properly. There are no windows or vents to allow adequate ventilation during temperature extremes and cleaning. We discussed adding an exhaust fan or a window to the building or screen door.

REPRESENTATIVE PRESENT FOR INSPECTION: **Tom Donaloio**
TITLE: **Dog Control Officer**

REVIEWED BY: **Inspector #: 64**
REVIEWED DATE: **08/10/2022**